

ECOANALYTIKAS WATER TESTING LAB

Approved by KSPCB



Report ID: ECO/31/05/825	Report Date:31/05/2024	Page 1 of 1

Customer Name &Address	SIVAGIRI VIDYANIKETAN SENIOR SECONDARY SCHOOL, VALMIKI HILLS, THOTTUMUGHOM, ALUVA - 683105		
Sample Name:	Water	Sample Received on	30/05/2024
Sample ID	EA/24/05/825	Test started on:	30/05/2024
Sample Description:	Well water	Test completed on:	31/05/2024
Sample Condition:	Good	Sample Drawn by	Lab
Sample quantity:	1L	Received Temperature	Ambient

SI No	Parameters	Test method	Unit	Result	Limit As per IS 10500
1	Colour	APHA 2120 B	Hz	1.00	Max 5
2	Odour	IS:3025 PART 6		Agreeable	Agreeable
3	pH	APHA 4500 H ⁺ B		6.64	6.5-8.5
4	Total Dissolved Solids	APHA 2540 C	mg/L	37.0	Max 500
5	Turbidity	APHA 2130 B	NTU	3.00	Max 1.00
6	Total Hardness as CaCO ₃	APHA 2340 C	mg/L	16.0	Max 200
7	Calcium as Ca	APHA 3500 B	mg/L	4.81	Max 75
8	Magnesium	APHA 3500 B	mg/L	1.00	Max 30
9	Chloride	APHA 4500 Cl B	mg/L	10.0	Max 250
10	Iron	APHA 3500 Fe B	mg/L	0.52	Max 0.3
11	Total Alkalinity as CaCO ₃	APHA 2320 B	mg/L	14.0	Max 200
12	Sulphate as SO ₄	APHA 4500 SO ₄ E	mg/L	2.50	Max 200
13	Total coliform bacteria	APHA 9222B	cfu/100ml	<1*	Absent/100ml
14	E. coli	APHA 9222G	cfu/100ml	<1*	Absent/100ml

<1* is equivalent to Absent or non-detectable.

Remarks: The given sample complies with all the above test parameters as per IS10500 except Turbidity and Iron.

DINCY DARVIN	ANNA FRANCIS > G	ANITHA KHADER
Chemist	Microbiologist	Lab Head Drug
Checked by:	Checked by	Authorized by:

Notes

- 1. The test result is pertained to the sample submitted only.
- 2. The sample will be retained for 15 days in chilled condition.
- 3. The test report shall not be produced except in full without the written permission of Lic.No.

END OF REPORT

Kuttamassery, Thottumugham P.O, Aluva 683105, Kerala Ph: +91 8089097776, +91 8281156578

Email: lab@eco-analytikas.com

License number: 400611/RPTL20/GPO/2024/2519

TAMASSERY, ALUN








ECOANALYTIKAS WATER TESTING LAB

Approved by KSPCB PCB/LAB/CO2/2023



Customer Name &Address	SIVAGIRI VIDYANIKETAN SENIOR SECONDARY SCHOOL, VALMIKI HILLS, THOTTUMUGHOM, ALUVA - 683105		
Sample Name:	Water	Sample Received on	30/05/2024
Sample ID	EA/24/05/826	Test started on:	30/05/2024
Sample Description:	Filter out	Test completed on:	31/05/2024
Sample Condition:	Good	Sample Drawn by	Lab
Sample quantity:	1L	Received Temperature	Ambient

SI No	Parameters	Test method	Unit	Result	Limit As per IS 10500
1	Colour	APHA 2120 B	Hz	1.00	Max 5
2	Odour	IS:3025 PART 6		Agreeable	Agreeable
3	pH	APHA 4500 H ⁺ B		6.71	6.5-8.5
4	Total Dissolved Solids	APHA 2540 C	mg/L	37.0	Max 500
5	Turbidity	APHA 2130 B	NTU	<1.00	Max 1.00
6	Total Hardness as CaCO ₃	APHA 2340 C	mg/L	16.0	Max 200
7	Calcium as Ca	APHA 3500 B	mg/L	4.81	Max 75
8	Magnesium	APHA 3500 B	mg/L	1.00	Max 30
9	Chloride	APHA 4500 Cl B	mg/L	10.0	Max 250
10	Iron	APHA 3500 Fe B	mg/L	0.20	Max 0.3
11	Total Alkalinity as CaCO ₃	APHA 2320 B	mg/L	16.0	Max 200
12	Sulphate as SO ₄	APHA 4500 SO ₄ E	mg/L	1.60	Max 200
13	Total coliform bacteria	APHA 9222B	cfu/100ml	<1*	Absent/100ml
14	E. coli	APHA 9222G	cfu/100ml	<1*	Absent/100ml

<1* is equivalent to Absent or non-detectable.

Remarks: The given sample complies with all the above test parameters as per IS10500.

DINCY DARVIN	ANNA FRANCIS	CON ANITHA KHADER
Chemist Draw	Microbiologist 💥	Lab Head Dirul
Checked by:	Checked by	Authorized by:

Notes

1. The test result is pertained to the sample submitted only.

The test result is periained to the sample submitted only.
The sample will be retained for 15 days in chilled condition.
The test report shall not be produced except in full without the written permissibility of the MASSERY, ALU.

END OF REPORT

Kuttamassery, Thottumugham P.O, Aluva 683105, Kerala Ph: +91 8089097776, +91 8281156578

Email: lab@eco-analytikas.com

License number: 400611/RPTL20/GPO/2024/2519

4CO-ANALYTIKAS LA